

# FLORIDA RURAL WATER ASSOCIATION

2970 WELLINGTON CIRCLE • TALLAHASSEE, FL 32309-7813  
(850) 668-2746

## MEMORANDUM

### BOARD of DIRECTORS

PATRICIA CICHON  
Monticello  
President

BRUCE MORRISON  
Niceville  
Vice President

WILLIAM G. GRUBBS  
Tallahassee  
Secretary/Treasurer

ROBERT MUNRO  
Orlando  
National Director

TOM JACKSON  
Fort Myers

SCOTT KELLY  
Atlantic Beach

BONNIE PRINGLE  
Rotonda West

EXECUTIVE  
DIRECTOR

GARY WILLIAMS  
Tallahassee



EMAIL  
[frwa@frwa.net](mailto:frwa@frwa.net)

WEBSITE  
[www.frwa.net](http://www.frwa.net)

TO FRWA Water Utility Member

FROM Gary Williams, Executive Director

SUBJECT FRWA Member Services

The Florida Rural Water Association performs member services, such as meter testing, ground penetrating radar locates, and many other onsite technical assistance activities for you at no charge.

We are sending this memo to you to inform you of a recent visit and service at your system. Please find attached a report of this effort.

This service was performed at your system at no charge from FRWA and you should not be charged by other agents, vendors, or companies for this service. If other agents, vendors, or companies were on-hand, requested by you or approved by you to oversee or be available for this effort and you approved expenses for that availability from them that is between you and them; but any charge should not include expenses for time of the FRWA service. That is a membership savings directly to you.

If FRWA can help your utility in anyway, please do not hesitate to contact us directly.

## **2021 Annual Drinking Water Quality Report**

### **Town of Inglis**

*We're pleased to present to you this year's **Annual Water Quality Report**. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water sources are groundwater from three wells drawing from the Floridan Aquifer. We treat our water using reverse osmosis, green sand filter for iron, polyphosphate for corrosion control, sodium hydroxide for pH control, and chlorinating for disinfection.*

*In 2021 the Department of Environmental Protection performed a Source Water Assessment on our system and a search of the data sources indicated 3 potential sources of contamination near our wells with a low level of susceptibility. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at [www.dep.state.fl.us/swapp](http://www.dep.state.fl.us/swapp).*

*This report shows our water quality results and what they mean.*

*If you have any questions about this report or concerning your water utility, please contact **Inglis Town Hall at (352) 447-2203**. We encourage our valued customers to be informed about their water utility. **Council meetings are held on the first Tuesday of every month at 6:00 pm.***

***The Town of Inglis** routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2021. Data obtained before January 1, 2021, and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.*

*In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions:*

***Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.*

***Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.*

***Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.*

***Maximum residual disinfectant level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.*

***Maximum residual disinfectant level goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.*

***Parts per billion (ppb) or Micrograms per liter ( $\mu\text{g}/\text{l}$ )** – one part by weight of analyte to 1 billion parts by weight of the water sample.*

***Parts per million (ppm) or Milligrams per liter ( $\text{mg}/\text{l}$ )** – one part by weight of analyte to 1 million parts by weight of the water sample.*

***Picocurie per liter (pCi/L)** - measure of the radioactivity in water.*

## Results Tables

<b>Inorganic Contaminants</b>							
Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Sodium (ppm)	11/2021	N	16.4	N/A	N/A	160	Salt water intrusion, leaching from soil

<b>Stage 1 Disinfectants</b>							
<i>For chlorine, the level detected is the highest running annual average (RAA), computed quarterly, of monthly averages of all samples collected. The range of results is the range of results of all the individual samples collected during the past year.</i>							
Disinfectant and Unit of Measurement	Dates of sampling (mo/yr)	MRDL Violation Y/N	Level Detected	Range of Results	MRDLG	MRDL	Likely Source of Contamination
Chlorine (ppm)	01/2021 – 12/2021	N	1.029	0.8 - 1.4	4	4.0	Water additive used to control microbes

<b>Stage 2 Disinfection By-Products</b>							
Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation (Y/N)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	9/2021	N	53.5	N/A	N/A	60	By-product of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	9/2021	N	23.2	N/A	N/A	80	By-product of drinking water disinfection

<b>Lead and Copper (Tap Water)</b>							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Violation Y/N	90 <sup>th</sup> Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Lead (tap water) (ppb)	10/2019	N	1.1	0	0	15	Corrosion of household plumbing systems. erosion of natural deposits
Copper (tap water) (ppm)	10 2019	N	0.121	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Inglis Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.*

*The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals*

and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply, we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

We at the **Town of Inglis** would like you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to insuring the quality of your water. If you have any questions or concerns about the information provided, please feel free to call any of the numbers listed.